



1ST FLOOR PLAN- ELECTRICAL
 SCALE: 1/4" = 1'-0"

PLAN NOTES:

1. REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT LOCATIONS OF ALL CEILING LIGHT FIXTURES.
2. ALL LIGHT FIXTURES ARE TYPE "A" UNLESS OTHERWISE INDICATED.
3. ALL EXIT SIGNS ARE TYPE "E" UNLESS OTHERWISE INDICATED.
4. RE-WORK EXISTING STAIRWAY LIGHTING CIRCUIT TO INCLUDE NEW 3-WAY SWITCHES AS INDICATED. ROUTE CONDUITS CONCEALED IN EXISTING WALL WHERE POSSIBLE, UTILIZE WIREMOLD TO CONCEAL WIRING WHERE ACCESS IS LIMITED.
5. EXISTING LIGHTING FIXTURE IN THIS ROOM/AREA TO BE REPLACED, REWORK CIRCUITING TO INCLUDE EXIT SIGNS, UTILIZE EXISTING CONDUITS WHERE POSSIBLE.
6. UTILIZE EXISTING CONDUIT SLEEVES FOR NEW WIRING.
7. CORE DRILL INTO CELL, HOLD NEW WALL MOUNTED FIXTURES CLOSE TO CEILING, COORDINATE EXACT LOCATION WITH OWNER/ARCHITECT PRIOR TO DRILLING/ROUGH-IN.
8. CORRIDOR CONDUITS TO BE ROUTED WITH EXISTING CONDUITS AND HELD TIGHT TO CEILING, UTILIZE STEEL CONDUIT AND BOXES TO MAINTAIN PERIOD LOOK, COORDINATE EXACT ROUTING WITH OWNER ARCHITECT PRIOR TO ROUGH-IN.
9. PROVIDE PERMANENT LABEL ON NEW SWITCH READING "CELL LIGHTS".
10. EXTEND NEW BRANCH CIRCUIT TO EXITING PANEL "A" AND MAKE CONNECTION TO SPARE 20A/1P CIRCUIT BREAKER, UP-DATE PANEL DIRECTORY.
11. TIE TO BRANCH CIRCUIT PREVIOUSLY SERVING THIS ROOM.

ROBERT L. HINKLE PE 29302
 POWELL & HINKLE ENGINEERING, P.A. GALTON C. MOK PE 33192
 1409 KINGSLEY AVENUE, BLDG 12A PE 46076
 ORANGE PARK, FLORIDA 32073 LANE R. HINKLE PE 56121
 THOMAS M. ELLER PE 56121
 8307 CYPRESS PLAZA DR., #203 JACKSONVILLE, FL 32256 * (904) 281-9002 * FL LIC. NO. AAC001107
 ENGINEERING CORPORATION FLA. REG. EP-16777 DAVID R. SPRELL JR. PE 54723
 JAMES L. HENNESSEY PE 63244

**BAKER COUNTY OLD JAIL - PHASE V REPAIRS
 FOR BAKER COUNTY, FLORIDA**
 MACLENNY, FLORIDA
 42 WEST McIVER AVENUE

**1ST FLOOR PLAN-
 ELECTRICAL AND NOTES**

DATE	03-01-2018
DRAWN BY	MH
CHECKED BY	TME
JOB NO.	#0217
REVISIONS	3-19-18
FILENAME	
SHEET NO.	

E-1