

ADDENDUM #1

to Bid Documents For:

County Road 23A from CR 125 to SR 121

Project #2020-06

Baker County, Florida

May 4, 2020

This addendum shall be considered part of the plans, specifications and contract documents and is issued to change, add or delete from or otherwise explain the documents further. This addendum shall have precedence over the original documents and shall govern.

Responses to questions

Question: I am not able to find a detail for FDOT pay item 400-2-12 trench slab. Can you provide a design for this pay item?

Response: The location and size of the trench slabs for protection of the 8" wm and 6" fm is shown on sheets 33,34 and 35.

