

ADDENDUM No. 1

to Bid Documents For:

CR 127 Rehabilitation Project – Phase 1

Baker County, Florida

Baker County Project No: 2020-14

October 7, 2020

This addendum shall be considered part of the plans, specifications and contract documents and is issued to change, add or delete from or otherwise explain the documents further. This addendum shall have precedence over the original documents and shall govern.

Questions (Q#) in bold precede responses (R#) in normal text.

Q1 Is there an engineer's estimate.

R1 There is no engineer's cost estimate, only an engineer's estimate of quantities.

Q2 Will there be additives (cement or bituminous) to the FDR? Is the intent of the plans to add limerock to the existing section and pulverize and reshape?

R2 No cement or bituminous additives are required for the FDR design. The intent of the plans is that 4" of limerock is to be added (overlaid) to the existing pavement section with this entire section then pulverized, mixed and compacted into an equivalent FDOT OBG 6 base layer to receive asphalt pavement.

Q3 Item 14 endwalls on the Bid Tabulation Form show units of "LF" for linear feet. Should units be "EA" for each?

R3 The units for Bid Item No. 14 should be "EA" and not "LF". A revised Bid Manual and Bid Forms are provided with this addendum.

Addendum Attachments:

CR127_BIDMANUAL_2020-10-07.pdf

CR127_BID_TAB_FORM_Addendum01.pdf

CR127_BID_TAB_FORM_Addendum01.xlsx

Addendum and attachments at: www.tarboxinc.com/CR127/