

BID PRICE SHEET

Baker County, FL

PURCHASE ONE NEW 4" HIGH VOLUME DOUBLE DIAPHRAGM PUMP

BID SPECIFICATIONS # 2021-16

Company Name: _____

Address: _____

Contact Name: _____

Phone Number: _____ Mobile Phone Number: _____

Email: _____

Tax ID# _____

Corporation or Partnership: _____

Number of Years in Business: _____

Signed: _____ Date: _____

	Item	Quantity	Bid Price
1	4" Double Diaphragm Pump	1	\$
2	4"x 20' Kanaflex Suction Hose	2	
3	4"x50' Heavy Duty Discharge Hose	1	
4	4" Small hole strainer	1	
		TOTAL	\$

Baker County, FL

PURCHASE ONE NEW 4" HIGH VOLUME DOUBLE DIAPHRAGM PUMP

MINIMUM BID SPECIFICATIONS # 2021-16

For one 4" Double Diaphragm Pump, Trailer Mounted

Pump Specifications:

- Steel casing
- 510 GPM pumping rate at 1950 RPM
- 4" solids handling
- Valve seats 3/8 stainless steel plate
- Diesel engine with at least 27 cubic inch displacement air cooled
- Hour meter
- Low oil pressure shutdown
- Trailer axle 3,500 lbs.
- 15-inch radial tires
- Camlock fittings
- Lockable fuel cap
- Fuel gage
- DOT trailer lights
- Powder coated trailer frame
- Minimum suction lift 31ft
- Fuel Capacity 40 gals
- Frame 8" square tubing
- Heavy duty single lifting point

Bidders must have a parts & services center within a 60-mile radius of Sanderson, FL 32087 that has a parts and services center for pump model being offered. Any current product data and warranty information must be submitted with bid. Bidders also must submit in their bid packet, information on any item that does not meet the minimum specifications listed above.