



# NFPS



PO BOX 3823  
LAKE CITY, FL 32056



PHONE (386) 752-4675  
FAX (386) 752-4674



[www.nfps.net](http://www.nfps.net)

December 4, 2023

**BAKER CO PROJECT: St Mary's Cove Boat Ramp Phase 1**  
**BAKER COUNTY BID NO: 2023-17**

## **ADDENDUM NO 3**

### **CLARIFICATIONS TO DRAWINGS**

1. On Sheet C-13, Details 2 and 3 of the Project Drawings, note that the cast-in-place concrete ramp sections shall be a minimum of 8 inches thick. The reinforcing steel shall be centered in the slab sections, and all reinforcement shall have a minimum of 2-inches cover, unless otherwise noted.

**END OF ADDENDUM 3**

(Please acknowledge receipt of Addendums)